

## Declaración de Conformidad *Conformity Declaration*

**Fabricante:** TECFLUID S.A.  
**Manufacturer:** Narcís Monturiol, 33  
E 08960 Sant Just Desvern

**Tipo de Equipo:** Automatismo  
**Type of Instrument:** Limit switch

**Modelo:**  
**Series:** 60-AMD, LT-AMD, LTL-AMD

### **Tipo de certificación:**

Los automatismos 60-AMD, LT-AMD y LTL-AMD contienen en su interior un detector inductivo de la marca Pepperl & Fuchs GmbH, modelo SJ3,5N, con certificado PTB 99 ATEX 2219 X, y cuyo marcado EEx es:

 2G EEx ia IIC T6

Por ser un aparato de seguridad intrínseca en un envoltente IP65, puede ser instalado en zona clasificada según el marcado del detector.

### **Type of Certification:**

The limit switches 60-AMD, LT-AMD and LTL-AMD contain inside an inductive detector from Pepperl & Fuchs GmbH, model SJ3,5N, with certificate PTB 99 ATEX 2219 X, and whose EEx marking is:

 2G EEx ia IIC T6

Given that it is an intrinsic safety apparatus enclosed in a IP65 housing, it can be installed in a classified zone in accordance to the marking of the detector.

En Sant Just Desvern  
Place:

Fecha: 12 de Marzo de 2009  
Date: March 12, 2009

Cargo:  
Position:

  
( firma ) ( Signature )  
Jordi Picazo Navalón  
( Nombre ) ( Full Name )  
Gerente  
Managing director